STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	155188	A. BUILDING 01 B. WING _____	R 02/13/2012

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
KINDRED TRANSITIONAL CARE AND REHAB-GREENFIELD	200 GREEN MEADOWS DR GREENFIELD, IN 46140

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
{K 000}	INITIAL COMMENTS A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 11/28/11 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a). Survey Date: 02/13/12 Facility Number: 000099 Provider Number: 155188 Aim Number: 100291140 Surveyor: Phillip Komsiski, Life Safety Code Specialist At this PSR survey, Kindred Transitional Care and Rehabilitation-Greenfield was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2. This one story facility was determined to be of Type V (111) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, spaces open to the corridors and none in resident sleeping rooms. The facility has a capacity of 197 and had a census of 155 at the time of this visit. Quality Review by Robert Booher, Life Safety Code Specialist-Medical Surveyor on 02/15/12.	{K 000}		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE | TITLE | (X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.